

Erin Bevis-Carver

From: Erin Bevis-Carver
Sent: Tuesday, March 11, 2014 5:58 PM
To: 'Douglas.Frasier@deq.virginia.gov'
Cc: Bob Custard; Lalit Sharma; William Skrabak; 'karen.pallansch@alexrenew.com' (karen.pallansch@alexrenew.com)
Subject: VPDES Permit VA008768
Attachments: DWO - CSO 004 - 03112014.doc

Doug –

In accordance with the requirements of Part II.G of the City's VPDES permit, this email is to inform you of a Dry Weather Overflow (DWO) that occurred at Outfall 004 into Hooff's Run earlier this afternoon. The cause of the DWO was a blockage of the siphons that convey flows from the City's CSS to the Commonwealth Interceptor and the AlexRenew Water Resources Recovery Facility. Maintenance crews cleared the blockage in the siphons and the DWO then ceased. An estimated 840 gallons was discharged into Hooff's Run. Attached is a copy of the DWO Reporting Form for your records. The City will follow-up with a 5-day letter.

Thanks,
Erin Bevis-Carver, P.E.
Civil Engineer IV
City of Alexandria, Virginia
T&ES/Engineering
703.746.4154
www.alexandriava.gov